


 <p>Delhi Jal Board</p>	<p>DELHI JAL BOARD (GOVT. OF N.C.T. DELHI) QUALITY CONTROL ZONAL LABORATORY (SOUTH) WATER WORKS OKHLA DELHI-110025</p>	 <p>भारतीय मानक ब्यूरो BUREAU OF INDIAN STANDARDS IS / ISO 9001 QMS</p>	 <p>स्वच्छ भारत एक कदम स्वच्छता की ओर</p>
	<p>Licence No- CRO/QM/L-8604290 IS/ISO 9001:2015</p>		

A.C.W.A.(South)/Paid/2025-26/P14-15/ Challan No.06 Dated 11.04.2025

Serial No.8163

Date-21.04.2025

<p>M/S G. D. Goenka Public School Sarita Vihar New Delhi-110076</p>

Date of sample collection : 16.04.2025


S.No	Characteristics	Unit	Acceptable Limit	UGT near Cafeteria	Water Dispensor near Room No 54 (Sports Room)
1.	Clarity	Unit	5	Clear	Clear
2.	Odour	---	Agreeable	No. Obj.	No. Obj.
3.	pH Value	---	6.5-8.5	7.5	6.8
4.	Conductivity	µmho/cm ²	---	873	87
5.	Total Dissolved Solids	mg/L	500	567	56
6.	Turbidity	NTU	1	1.61	0.81
7.	Phenolphthalein Alkalinity	mg/L	----	NIL	NIL
8.	Total Alkalinity (as CaCO ₃)	mg/L	200	250	28
9.	Total Hardness (as CaCO ₃)	mg/L	200	216	12
10.	Carbonate hardness	mg/L	----	216	12
11.	Non- Carbonate Hardness	mg/L	----	Nil	Nil
12.	Calcium Hardness	mg/L	----	114	08
13.	Magnesium Hardness	mg/L	----	102	04
14.	Ammonia (as Total N)	mg/L	0.5	ND	ND
15.	Nitrite (as N)	mg/L	----	ND	ND
16.	Nitrate	Mg/L	45	32.6	9.3
17.	Chloride (as Cl)	mg/L	250	64	10
18.	Calcium (as Ca)	mg/L	75	45.6	3.2
19.	Magnesium (as Mg)	mg/L	30	24.48	0.96
20.	Sulphate (as SO ₄)	mg/L	200	44	08
21.	Fluoride	mg/L	1.0	0.53	0.10
22.	Iron	Mg/l	1.0	0.06	0.02
23.	Free Residual Chlorine	mg/L	0.2	0.75	Nil


ACWA(SOUTH)




Dr. D. P. SINGH
ACWA (SOUTH ZONE)
Delhi Jal Board
Govt. of NCT of Delhi


CHEMIST


A/CHEMIST

“STOP CORONA VIRUS-Wash Your Hand/Wear Mask/Maintain Social Distance”

 Delhi Jal Board	<p>DELHI JAL BOARD (GOVT. OF N.C.T. DELHI) QUALITY CONTROL ZONAL LABORATORY (SOUTH) WATER WORKS OKHLA DELHI-110025</p> <p>भारतीय मानक ब्यूरो IS / ISO 9001 BUREAU OF INDIAN STANDARDS QMS</p> <p>Licence No- CRO/QM/L-8004290 IS/ISO 9001:2015</p>	 एक कदम स्वच्छता की ओर
---	--	--

BACTERIOLOGICAL ANALYSIS REPORT

Dated: 19.04.2025

No. DJB/DTQC/ CWA (W&S)III /ACWA (south)/ Bact/P.S./2024-2025/14-15/16.04.2025

Bacteriological Analysis Report as per IS 10500:2012

To M/S – G D Goenka Public School, Sarita Vihar New Delhi -110076	Party Ref.No./Date: GDGPS/SV/2025- 26/2601/11.04.2025 Dept. Challan No. /date: 06/11.04.2025 Dt.of sample collection: 16.04.2025 No. of Sample: Two (02) Collected by: Name- Mrs. Shweta Kirad Desig. - Asst. Bacteriologist
--	--

S.No.	Particulars	Clarity	Residual chlorine	Total Coliform Count/ 100 ml sample
1.	UGT Near Kitchen Cafeteria	Clear	0.75	0
2.	Water Dispenser New Room(Sports Room)	Clear	Nil	0

RESULT: -Collected water samples as mentioned above at S.No. 1&2 were found bacteriological satisfactory; hence the water/source are fit for drinking/recreational purpose subject to satisfactory attached Physical-Chemical Analysis report also.


19/4/25

ACWA (SOUTH ZONE)




Dr. D. P. SINGH
ACWA (SOUTH ZONE)
Delhi Jal Board
Govt. of NCT of Delhi


19/04/25

BACTERIOLOGIST (SOUTH ZONE)



MANESHWAR DIXIT
BACTERIOLOGIST (SOUTH ZONE)
Delhi Jal Board
Govt. of NCT of Delhi


19/4/25

ASST./BACT.